

Diocesan Advisory Committee for the Care of Churches

10am, Monday 12th September 2022, Christ Church Keene Room

MINUTES

Welcome and Apologies

Attendees:

Sophie Hammond, James Mackintosh, Bryan Martin, John Missenden, Revd Canon Dr Peter Groves, Mike Holmes, Julian Munby, Liz Kitch, Revd Canon Jeff West, Carolyn Jupe, Charlotte Robinson, Revd Canon David Tyler, Ven Judy French, Abigail Lloyd, Jennie Schillig, Andrea Ford, Hannah Robertson, Ven Guy Elsmore, Katie Tupling, Helen Ensor

Apologies:

The Ven Jonathan Chaffey, David Mason, Peter Preston

1	Minutes of meeting held on 18th July 2022		Approved
2	Declarations of interest		None
3	Correspondence, policy and other matters for consideration		
3.1	<i>Reporting line of Church Buildings Team The DAC is to join the Secretariat team from January 2023, reporting to Mark Humphriss. This will enable closer links with the Pastoral Secretary and those involved in funding/grants.</i>	LK	Verbal report
3.2	<i>Thanks were given to the Ven Judy French for all that she has done and well wishes for her forthcoming retirement</i>		
3.3	<i>Staff News – Andrea Ford to be leaving the DAC in Autumn. We thank her for all that she has brought to the DAC and wish her well in her new role.</i>		
4	Applications submitted to DAC since the last agenda	Chair	Page 2
5	Casework - Returning		
	<i>Longworth St Mary</i>	LK	Page 2
	<i>Pyrton St Mary</i>	JS	Page 3
	<i>Crowmarsh Gifford St Mary Magdalen</i>	JS	Page 4
6	Casework - New proposals		
	<i>Great Brickhill St Mary</i>	HR	Page 5
	<i>Hardwick cum Tusmore St Mary</i>	JS	Page 5
	<i>Woodley St John the Baptist</i>	HR	Page 6
	<i>Langford St Matthew</i>	HR	Page 6
7	Pre - application and technical site visits to note	Chair	
8	List Bs and NOAs issued under subcommittee and delegated authority since last meeting	Chair	
9	Completed project feedback	Chair	

Dates of future meetings:

- Monday 14th November 22, 10.00am – McKenna Room, Christ Church
- Monday 16th January 23, 10.00am – McKenna Room, Christ Church
- Monday 13th March 23, 10.00am – McKenna Room, Christ Church
- Monday 8th May 23, 10.00am – McKenna Room, Christ Church
- Monday 17th July 23, 4.00pm – Freind Room, Christ Church

4	Applications submitted to DAC since the last agenda
---	--

	List B (DAC)	List B (Arch)	Faculty DA	Faculty Minor	Faculty Major	Interim/PP/Variation	Early stage Enquiry	Total
June 2022	28	20	16	18	10	4	25	121
July 2022	26	16	11	7	9	4	31	104
Aug 2022	21	11	14	17	7	5	25	100

5	Casework - Returning
---	-----------------------------

Longworth, St Mary			
---------------------------	--	--	--

2016-002600	Dorchester	Grade I	LK
-----------------------------	------------	---------	----

Statutory consultees:	Historic England, SPAB, LPA, CBC
-----------------------	----------------------------------

Reviewing members:	Abigail Lloyd, Alan Frost, Julian Munby, James Mackintosh
--------------------	---

Project architect:	David Arnold, Whites of Appleton
--------------------	----------------------------------

Proposals:	Removal of existing bell frame (certain elements to be retained and displayed). Installation of new frame and increase the ring from 5 to 8 bells. Sound attenuation measures and tower repairs. Previous 2017 version of the scheme did not include sound attenuation or tower repairs and only included the introduction of one further bell, which has now been cast.
------------	--

Previous DAC Minute:	<p>May 2017:</p> <p>The principle of the restoration of the bells and reinstatement of ringing at Longworth is understandable and encouraged by the DAC. It is recommended that the parish provide the following information in preparation for submitting their faculty application online.</p> <ul style="list-style-type: none"> • Demonstrate by means of a sectional drawing that the existing bell frame cannot be elevated above the ringing chamber or kept in its current position with a new frame installed above. • A firm and detailed proposal for the relocation of the existing bell frame. • A statement of need that explains the justification for the plans. This must include the reasoning behind increasing the bell ring to six and an explanation of the number of bell ringers at Longworth whom are committed to the long-term future of bell-ringing at St Mary's. • As sally guides will need to be installed to enable ringing from the body of the church and elevation of the west wall as existing and proposed should be provided, demonstrating the height of the sally guide and any interference this will have on the window. • To be included within the statement of need or a separate document, the parish must show that they have considered the comments from the Church Building's Council and have either accepted them or are giving reason to contest them.
----------------------	---

Sept 22 Minute:	
-----------------	--

The DAC resolved to support the principle of the scheme but expressed concern about the viability of income generation from the establishment of a ringing school at the church. Fresh consultations with local residents should take place as early as possible, and the parish may wish to temporarily install a speaker system to replicate the expected volume and frequency of bell ringing. The DAC resolved to delegate the consideration of details of the scheme, particularly the treatment of the tower steps, decision on what elements of the frame are to be retained within the church (following full archaeological investigation being undertaken during the dismantling)

details of the sound attenuation methods proposed and the specification for the tower repairs, to a sub committee prior to a supportive Notification of Advice being issued.

Pyrton, St Mary

2022-073289	Dorchester	Grade II*	JS
Statutory consultees:	Historic England, SPAB, Vic Soc, LPA		
Reviewing members:	Julian Munby, Peter Preston, David Tyler		
Project architect:	John Radice		
Proposals:	Revised proposals for upgrading of lighting, heating and existing servery, reordering of pews to provide front dais		
Previous DAC Minute:	<p>July 2015 minute: Detailed proposals were first considered by the DAC in early 2015, when the committee requested that every effort be made to retain the maximum number of pews given that some contain medieval fabric, and that the others appear to have been modelled on these medieval fragments. The committee heard that the parish had therefore revised the number of pews to be removed down to three. Two would be the two easternmost pews in the nave. These would be replaced by two partially medieval pews (numbered 25 and 26) from the west end. 25 could be relocated without alteration, but the end of 26 would need to be refitted at the other end of the bench. It was clear to the delegation that this end had been rehanded before, as a notch matching the back rail of the pew had been filled with a more recent (likely 19th century) piece of timber. The third pew for removal (number 23) was also Victorian and of one phase. The committee noted that the parish also wished to remove a rough early 19th century bench with an open back, in extremely poor condition - this would be sold.</p> <p>Of the three other west end pews to be relocated, number 24 (medieval seat and back panels) would be placed next to the font, number 27 (medieval seat but otherwise Victorian) would be placed in the meeting room against the wall</p> <p>The committee had also raised the issue of ventilation to the WC, and the architect has agreed this can go through the wall beneath ground level, and then up and out to the exterior using an existing redundant pipe.</p> <p>It was agreed to recommend the proposals as presented; subject to construction, finish, and section details being submitted for approval by the DAC officers in due course.</p> <p>November 2019 minute: The DAC considered that of the options presented 'B' was more practical however felt that the scheme for which faculty permission was granted in 2014 presented a less visually cumbersome design and, given the large quantities of angled timber paneling in the present options, may not be significantly more costly. A bell hanger should be consulted to ensure it is possible to relocate the bell ropes as suggested in option 'B'. This should be done as a next step to establish whether this design option must be ruled out as a result.</p>		

	<p>The DAC encouraged the parish to develop their Statements of Significance and Need but resolved that, should the SCBO be content that these documents clearly demonstrated an ongoing need from that established in 2014, then a supportive Notification of Advice for either option 'B' or the 2014 scheme could be issued upon receipt of the necessary technical details. In either case the amenity societies will need to be reconsumed, and it may be beneficial to ask them to comment on both the present and 2014 options to inform the PCCs decision when selecting which version of the scheme to progress with.</p> <p>The DAC noted that a plastic folding chair was not felt appropriate for use in the historic church and, as there are not many required, suggested the parish consider the unupholstered timber Treske folding chair which would continue to provide temporary seating with a minimal storage requirement but in a more appropriate material.</p>
--	--

September 22 Minute:

The DAC resolved issue a Recommend Notification of Advice subject to the following provisos:

- Detailed proposals for the infill of the aisle to create a dais and making good of the base of the pulpit to be submitted for approval by the subcommittee prior to works commencing on site.
- Cable routes for new lighting to be agreed with the project architect in advance.
- Electrical works to be in accordance with the diocesan electrical guidelines.
- The proposed heating installation to be in accordance with the proposal from Cooltouch.
- Repairs to the font are not included in this consent.
- It is suggested that an acoustician is asked to analyse the impact of inserting an enclosure for facilities at the west end of the church.
- It is suggested that the parish establish how much the Royal Academy are likely to continue to use the church for concerts and recording.
- It should be noted that the single remaining pew door was attached to one of the pews to be relocated. This should be retained and relocated if possible.

Crowmarsh Gifford, St Mary Magdalene

2022-073040	Dorchester	Grade I	JS
-----------------------------	------------	---------	----

Statutory consultees:	Historic England, SPAB, LPA, CBC
-----------------------	----------------------------------

Reviewing members:	Julian Munby, Peter Preston, David Tyler
--------------------	--

Project architect:	Robert Montgomery
--------------------	-------------------

Proposals:	Provision of WC and servery at west end of church
------------	---

Previous DAC Minute:	<p>May 2004 minute:</p> <p>The delegation reported on proposals to create a gallery with WC and tea-making facilities below at the west end of the church. It was also intended to make the existing vestry secure to allow the church to be open during the day. Consideration was also being given to opening the blocked south doorway and inserting glazing to give a more open feel to the church. This would require a careful design and there would need to be consultation with the planning authority and others. The DAC considered that the right approach was being taken to meet the needs of the congregation and encouraged the parish to develop the designs.</p>
----------------------	--

September 22 Minute:

Subject to consultation with Historic England and the relevant amenity societies, a Recommend Notification of Advice could be issued subject to the parish agreeing to make the following amendments:

- Options for providing a fully accessible WC are explored further. This may result in the need to relocate the font or site the WC on the south side of the nave.
- The proposals should be revised to provide a symmetrical enclosure on both sides of the central entrance.

6	Casework - New
---	-----------------------

Great Brickhill, St Mary			
2022-074014	Buckingham	Grade II*	HR
Statutory consultees:	Historic England, SPAB, LPA		
Reviewing members:	Peter Preston, James Mackintosh, Valerie Plumb, Guy Elsmore		
Project architect:	Stimpson Walton Bond		
Proposals:	To re-roof the north and south aisles with terne coated stainless steel with an acoustic underlay		
September 22 Minute:			
<p>The DAC resolved to recommend the proposal for faculty.</p> <p>In regard to the lead gutter, it was highlighted that terne coated stainless steel in contact with lead can accelerate the corrosion process of the metals, ultimately resulting in early failure of the gutters. Therefore, it was recommended that this matter was discussed with the architect to determine whether the lead gutter ought to be replaced altogether with terne coated stainless steel.</p>			

Hardwick-cum-Tusmore, St Mary the Virgin			
2022-076141	Dorchester	Grade II	JS
Statutory consultees:	SPAB, Vic Soc, LPA		
Reviewing members:	Abigail Lloyd, Peter Preston, David Tyler		
Project architect:	Bryan Martin		
Proposals:	Removal of pews from south aisle and reconfiguration of existing vestry enclosure to provide WC with servery in the south aisle.		
September 22 Minute:			
<p>The DAC resolved to accept the recommendations contained in the CBO's site visit report. The parish is encouraged to continue to develop options 8, 8A or 8B. The issues raised by the Victorian Society should be taken into account during this process.</p>			

Woodley, St John the Baptist			
2022-074717	Berkshire	Grade II*	HR
Statutory consultees:	Victorian Society, Historic England, LPA		
Reviewing members:	Stephen Pullin, John Missenden, Helen Ensor		
Project architect:	No architect appointed		
Proposals:	Removal of six pews from the nave following their provisional removal under a temporary minor reordering license.		

September 22 Minute:

The DAC resolved to recommend the proposal for faculty.

Langford, St Matthew

2022-071395	Dorchester	Grade I	HR
Statutory consultees:	Historic England, Victorian Society, LPA		
Reviewing members:	Judy French, David Tyler, Abigail Lloyd		
Project architect:	No architect appointed		
Proposals:	Removal of pews from nave and aisles and introduction of 60 Howe 40/4 stackable chairs.		

September 22 Minute:

Archdeacon Judy French gave her thoughts on the parish and their ambitions having visited the church in late 2021. She emphasized that this application was just the beginning of a long-term plan to secure the future of the church. She expressed her support for their proposal.

The committee resolved to discuss the case again in November following a delegation site visit to the church.

7 Pre-application and technical site visits to note (30th June - 26th August)

05.07.22	North Crawley St Firmin	WC & Kitchen	JS
12.07.22	Culham St Paul	Reordering	HR
19.07.22	Hardwick-cum-Tusmore St Mary	New facilities	JS
10.08.22	Woodstock St Mary	Timber Dais	SH
10.08.22	North Aston St Mary the Virgin	Lychgate restoration & access	SH
11.08.22	Brightwell St Agatha & Sotwell St James	Condition & facility survey	LK
23.08.22	Longworth St Mary	Bells project	LK
23.08.22	Crowmarsh Gifford St Mary Magdalene	WC & Servery	JS
23.08.22	Pyrton St Mary	Development	JS
25.08.22	Oxford St Peter's College	Sound System	SH

8 List Bs and NOAs issued under subcommittee and delegated authority since last meeting

Parish	Archdeaconry	Listing	App Ref	Type	Case type	Works	Status
Weston-on-the-Green: St Mary	DORCHESTER	Grade II*	2022-073614	Faculty - DA	Liturgical	Retrospective Replacement curtain behind altar	NOA issued
Dorchester: St Peter & St Paul MAJOR PARISH CHURCH	DORCHESTER	Grade I	2021-058454	Faculty - DA	PP & M	Memorial plaque - Richard Beauforest	NOA issued

Frieth: St John the Baptist	BUCKINGHAM	Grade II	2022-071794	Faculty - DA	R&C	Retrospective roof repairs	Petition submitted to Dio Reg
Steeple Aston: St Peter & St Paul	DORCHESTER	Grade II*	2022-074466	Faculty - DA	Churchyard	Retrospective planting of tree	NOA issued
Chalvey: St Peter	BUCKINGHAM	Grade II*	2020-052937	Faculty - DA	Churchyard	Repair/replace path	NOA issued
Edgcott: St Michael & All Angels	BUCKINGHAM	Grade II*	offline	Faculty - DA	Heritage Crime	Temporary covering of felt to nave roof following lead theft	Interim faculty issued
Ewelme: St Mary the Virgin	DORCHESTER	Grade I	2021-058641	Faculty - DA	Churchyard	Replace 3 boundary stones on the memorial garden	NOA issued
Cadmore End: St Mary le Moor	BUCKINGHAM	Grade II	2022-073161	Faculty - DA	Lighting	Replacement lighting with LED	Petition submitted to Dio Reg
Slapton: Holy Cross	BUCKINGHAM	Grade II*	2022-075349	Faculty - DA	R&C	To regularise interim - south wall repairs	Faculty issued
Reading: St Mary the Virgin	BERKSHIRE	Grade I	2022-074742	Faculty - DA	Churchyard	Lamps in churchyard re recent stabbings	Faculty issued
Henley-on-Thames: St Mary the Virgin MAJOR PARISH CHURCH	DORCHESTER	Grade II*	2022-071707	Faculty - DA	H&S improvements	Pigeon netting	Faculty issued
Leafield: St Michael & All Angels	DORCHESTER	Grade II*	2021-067014	Faculty - DA	M&E	Replacement of heating	Petition submitted to Dio Reg
Milton Keynes Village: All Saints	BUCKINGHAM	Grade I	2022-072038	Faculty - DA	Churchyard	Area for interment of cremated remains	Faculty issued
Olney: St Peter & St Paul	BUCKINGHAM	Grade I	2022-071443	Faculty - DA	Seating	New chairs	NOA issued
Bletchley: St Mary	BUCKINGHAM	Grade I	2022-072605	Faculty - DA	Churchyard	Work to Cohen memorial	Petition submitted to Dio Reg
Cropredy: St Mary the Virgin	DORCHESTER	Grade I	2021-063512	Faculty - DA	Churchyard	Permanent setting for Christmas Tree	NOA issued with provisos
Akeley: St James	BUCKINGHAM	Ungraded	2020-053420	Faculty - Major	Development	New churchyard building/structure for worship and associated landscaping	NOA issued with provisos
Eton Wick: St John the Baptist	BUCKINGHAM	Grade II	2019-033948	Faculty - Major	Development	redevelopment of church room attached to the church	NOA issued
Bix: St James	DORCHESTER	Grade II	2022-073525	Faculty - Major	Seating	Removal of pews to enable flexible space and for additional heaters to be added to perimeter walls	NOA issued with provisos
Upton: St Mary the Virgin	DORCHESTER	Grade II*	2022-072791	Faculty - Major	Development	Downscale previous faculty re funding - new facilities without extension	NOA issued with provisos
Oxford: St Michael at the North Gate	OXFORD	Grade I	2022-070367	Faculty - Minor	Liturgical	Laying of Standard	NOA issued
Great Coxwell: St Giles	DORCHESTER	Grade II*	2022-072981	Faculty - Minor	H&S improvements	Handrail alongside the altar steps	Faculty issued

Oxford: St Aldate	OXFORD	Grade II*	2022-071823	Faculty - Minor	Lighting	Replacement of lighting, sound and AV systems	Faculty issued
Beaconsfield: St Mary & All Saints	BUCKINGHAM	Grade II*	2022-071083	Faculty - Minor	H&S improvements	Safety rail for organ platform	NOA issued
Lockinge: All Saints	DORCHESTER	Grade II*	2021-068155	Faculty - Minor	OBC	Installation of electronic organ and removal of old console	NOA issued
East Garston: All Saints - HAR	BERKSHIRE	Grade II*	2022-074789	Faculty - Minor	Churchyard	Boundary cob/witchert wall repairs	NOA issued
South Ascot: All Souls	BERKSHIRE	Grade II*	2019-034369	Faculty - Minor	M&E	Replacement heating system	Faculty issued
Long Crendon: St Mary the Virgin	BUCKINGHAM	Grade I	2022-073558	Faculty - Minor	Heating	Heating - cast iron radiators	Faculty issued
Henley-on-Thames: St Mary the Virgin MAJOR PARISH CHURCH	DORCHESTER	Grade II*	2022-069179	Faculty - Minor	Liturgical	Embroidered panels	Faculty issued
Henley-on-Thames: St Mary the Virgin MAJOR PARISH CHURCH	DORCHESTER	Grade II*	2022-074011	Faculty - Minor	OBC	Overhaul clock and silencing mechanism	Registrar to issue faculty
Little Milton: St James	DORCHESTER	Grade II	2022-075122	List B	M&E	Installation of under pew heaters	List B issued
Lambourn: St Michael & All Angels	BERKSHIRE	Grade I	2022-072872	List B	R&C	Plaster repairs	List B issued
Wokingham: All Saints	BERKSHIRE	Grade II*	2022-073481	List B	OBC	Replacement electronic organ	List B issued
Swinbrook: St Mary	DORCHESTER	Grade II*	2022-070401	List B	AV	New Sound System	List B issued
Abingdon: St Helen MAJOR PARISH CHURCH	DORCHESTER	Grade I	2022-072270	List B	OBC	Organ repairs	List B issued
Witney: St Mary the Virgin MAJOR PARISH CHURCH	DORCHESTER	Grade I	2022-074597	List B	AV	Replacement audio and visual streaming systems	List B issued
Cropley: St Mary the Virgin	DORCHESTER	Grade I	2022-076083	List B	AV	Telephone installation	Awaiting Archdeacon
High Wycombe: All Saints MAJOR PARISH CHURCH	BUCKINGHAM	Grade I	2022-075531	List B	Churchyard	Repairs to 18th century gates	Awaiting Archdeacon
Towersey: St Catherine	DORCHESTER	Grade II	2022-074285	List B	Churchyard	Wall repair	List B issued
Hitcham: St Mary	BUCKINGHAM	Grade I	2022-074059	List B	R&C	Several replacement roof tiles	List B issued
Bray: St Michael	BERKSHIRE	Grade II*	2022-072093	List B	R&C	Repair and refurbishment of windows	List B issued
Mursley: St Mary the Virgin	BUCKINGHAM	Grade II*	2022-075795	List B	R&C	QI Repairs	Awaiting Archdeacon
Barford: St Michael (Parish considering closure)	DORCHESTER	Grade I	2022-068372	List B	R&C	Redecoration and repairs of CI RWG	List B issued
Oxford: St Thomas the Martyr HAR	OXFORD	Grade II	2022-074891	List B	R&C	Re-cover roof	List B issued
Wheatfield: St Andrew	DORCHESTER	Grade I	2022-073623	List B	R&C	Internal redecoration following roof work	List B issued

Black Bourton: St Mary the Virgin	DORCHESTER	Grade I	2022-074438	List B	Heating	New electrical heating system	List B issued
Ewelme: St Mary the Virgin	DORCHESTER	Grade I	2022-072316	List B	R&C	Tower Repair	List B issued
Watlington: St Leonard	DORCHESTER	Grade II*	2022-072436	List B	Churchyard	Treeworks	List B issued
Kingham: St Andrew	DORCHESTER	Grade II*	2022-071879	List B	Churchyard	Bench	List B issued
Reading: St Laurence	BERKSHIRE	Grade I	2022-071793	List B	R&C	Replaster & repaint where necessary	List B issued
Chalfont: St Giles	BUCKINGHAM	Grade I	2022-073054	List B	Churchyard	Felling 2 willow trees	List B issued
Drayton: St Peter	DORCHESTER	Ungraded	2022-074107	List B	R&C	Replace guttering	List B issued
Newport Pagnell: St Peter & St Paul	BUCKINGHAM	Grade I	2022-073032	List B	R&C	Vestry refurbishment	List B issued
Haddenham: St Mary the Virgin	BUCKINGHAM	Grade I	2022-074913	List B	Churchyard	Replace old noticeboards in lychgate	List B issued
Crowthorne: St John the Baptist	BERKSHIRE	Grade II	2022-075203	List B - Archdeacon	Churchyard	Bench re 150th anniversary	List B issued
Dry Sandford: St Helen	DORCHESTER	Grade II	2022-074577	List B - Archdeacon	Churchyard	Installation of Commonwealth War Graves Commission Sign	List B issued
Westcott: St Mary	BUCKINGHAM	Grade II*	2022-074578	List B - Archdeacon	Churchyard	Installation of Commonwealth War Graves Commission Sign	List B issued
Chipping Norton: St Mary the Virgin	DORCHESTER	Grade I	2022-075246	List B - Archdeacon	Churchyard	Felling dangerous silver birch (retrospective)	List B issued
Twyford: Assumption of the Blessed Virgin Mary	BUCKINGHAM	Grade I	2022-075322	List B - Archdeacon	Churchyard	Removal of overhanging tree	Awaiting Archdeacon
Souldern: Annunciation of the Blessed Virgin Mary	DORCHESTER	Grade II*	2022-075826	List B - Archdeacon	Churchyard	Felling of a dangerous tree	List B issued
Wallingford: St Leonard	DORCHESTER	Grade II*	2022-075642	List B - Archdeacon	Churchyard	Prune trees in churchyard	Awaiting Archdeacon
Clewer: St Stephen	BERKSHIRE	Grade II	2022-075328	List B - Archdeacon	AV	Add camera to new sound system to aid videoing of streamed services	Awaiting Archdeacon
Marston: St Nicholas	OXFORD	Grade I	2022-074031	List B - Archdeacon	New facilities	Bike racks & hoops	Awaiting Archdeacon
Chinnor: St Andrew	DORCHESTER	Grade I	2022-075131	List B - Archdeacon	Churchyard	Removal & replacement of bench	List B issued
Tilehurst: St Catherine of Siena	BERKSHIRE	Ungraded	2022-075202	List B - Archdeacon	Churchyard	Noticeboard	List B issued
Warfield: St Michael the Archangel	BERKSHIRE	Grade II*	2022-074621	List B - Archdeacon	Churchyard	Fell one tree	List B issued
Ashley Green: St John the Evangelist	BUCKINGHAM	Grade II*	2022-073790	List B - Archdeacon	Churchyard	Noticeboard	List B issued
Thame: St Mary the Virgin	DORCHESTER	Grade I	2022-074905	List B - Archdeacon	Churchyard	Introduction of a memorial bench in the churchyard Fane	List B issued
Thame: St Mary the Virgin	DORCHESTER	Grade I	2022-074904	List B - Archdeacon	Churchyard	Introduction of a memorial bench in the churchyard Lewis	List B issued

Hanslope: St James the Great	BUCKINGHAM	Grade I	2022-074620	List B - Archdeacon	Churchyard	Installation of bench in churchyard	List B issued
Henley-on-Thames: St Mary the Virgin MAJOR PARISH CHURCH	DORCHESTER	Grade II*	2022-074448	List B - Archdeacon	M&E	Alteration to lightening protection system	List B issued
Quainton: Holy Cross & St Mary	BUCKINGHAM	Grade I	2022-074373	List B - Archdeacon	Churchyard	Felling 2 trees	List B issued
Bampton Proper: St Mary	DORCHESTER	Grade I	2022-074539	List B - Archdeacon	Churchyard	Removal and replacement of a dead tree in a conservation area	List B issued
Thame: St Mary the Virgin	DORCHESTER	Grade I	offline	Private Petition	PP & M	Memorial outside regs - Sweby	NOA issued
Fulmer: St James	BUCKINGHAM	Grade II*	offline	Private Petition	Churchyard	Memorial outside regs - Arthur	NOA issued
Burford: St John the Baptist	DORCHESTER	Grade I	offline	Private Petition	Churchyard	Memorial outside regs - Tickell	NOA issued with provisos
Cadmore End: St Mary le Moor	BUCKINGHAM	Grade II	2022-075182	TRO	Reordering	Temporary removal of three pews at west end of nave	Awaiting Archdeacon
Asthall: St Nicholas	DORCHESTER	Grade II*	2021-065229	Variation	Churchyard	Replacement capping stones for retaining wall	Awaiting Diocesan Registry

9

Completed project feedback

Reading Holy Trinity – Completed repair of Statue



Westcott, St Mary – Reordering including partial pew removal of Street interior



Aylesbury, St Mary – completed repair of chancel roof and tower stonework

